

# Measurement & Verification

“You cannot manage what you do not measure” – Jack Welch, former CEO, General Electric

# What is M&V?

- “The process of using measurements to reliably determine actual savings created within an individual facility by an energy management program”

Source: IPMVP Volume I – September, 2009

# Why Measure & Verify?

- Increase energy savings due to reporting feedback (uncovers new opportunities)
- Creates persistence of energy savings
- Reduce financial risk and create a base for negotiations with energy performance contracts
- Improves credibility of energy efficiency
- LEED EB O&M requires M&V for EA Credit 2.3 “Ongoing Commissioning”
- Pay-for-performance incentives for RCx

# EVO and IPMVP

- Efficiency Valuation Organization (EVO)
  - Established to create standards which assist with risk and benefit management in the context of energy efficiency
- International Performance Measurement and Verification Protocol (IPMVP)
  - Created to support and promote energy efficiency and renewable energy worldwide
- Latest Version of Vol. I - January 2012

# Elements of M&V

## ■ The M&V Plan

- Prior to project implementation
- Establishes method for measuring and adjusting energy use to verify savings
- Documents requirements for M&V Reports

## ■ The M&V Report

- Periodic documentation of observed energy use and verified savings after project implementation
- Includes justification for usage adjustments

# IPMVP Options

- The “best” option depends on...
  - Budget
  - Metering
  - Scope of EEM(s)
- Multiple Options may be used within an M&V Plan, depending on the considerations above

# IPMVP – Option A

- “Retrofit Isolation: Key Parameter Measurement”
  - Baseline is an engineering calculation which could involve short-term metering, continuous metering, or an engineering estimate
  - Good for measures with consistent energy consumption (i.e. lighting, constant speed fans)

# IPMVP – Option B

- “Retrofit Isolation: All Parameter Measurement”
  - Energy use is either measured directly or a calculation *which is based on a measurement*
  - Good for systems with known performance curves where an isolated measurement can be used to calibrate energy consumption (i.e. VSDs)



# IPMVP – Option C

- “Whole Facility”

- Energy use metered at the whole facility level or sub-facility level
- Good for complex EEMs which affect multiple systems

# IPMVP – Option D

- “Calibrated Simulation”
  - Energy use is simulated with energy modeling software (such as eQUEST or EnergyPro) and calibrated using monthly utility bills
  - Good for facilities where no baseline data is available (i.e. new construction)

# Creating an M&V Plan

- 1) Create a list of building systems and system components with their energy consumption characteristics (power draw, firing rates, etc.)
- 2) Determine goals for M&V (specific EEM isolation = Options A & B, whole facility = Options C &D)

# Creating an M&V Plan

- 3) Determine which quantities need to be metered and which can be estimated (if using Option A or B)

Table 2 Example Lighting	Situation	Measurement vs. Estimation Strategy		Adherent to Option A?
		Operating Hours	Power Draw	
	<i>ECM</i> reduces operating hours	Measure	<i>Estimate</i>	Yes
		<i>Estimate</i>	Measure	No
	<i>ECM</i> reduces power draw	<i>Estimate</i>	Measure	Yes
		Measure	<i>Estimate</i>	No
<i>ECM</i> reduces both power draw and operating hours:				
	<i>Baseline</i> power uncertain, operating hours known	<i>Estimate</i>	Measure	Yes
		Measure	<i>Estimate</i>	No
	Power known but operating hours uncertain	Measure	<i>Estimate</i>	Yes
		<i>Estimate</i>	Measure	No
	Power and operating hours poorly known	Measure	<i>Estimate</i>	No – Use Option B
		<i>Estimate</i>	Measure	

# M&V Plan Contents

- 1) ECM Description, Intent, and Commissioning Procedure
- 2) Select IPMVP Option and Measurement Boundary
- 3) Baseline Conditions: Include energy use and quantify factors which affect energy use

# M&V Plan Contents

- 4) Identify the reporting period
- 5) Identify whether data will be normalized (if so, savings will be “normalized savings”, if not savings will be “avoided energy use”)
- 6) Analysis Procedure: define all mathematical models to be used and any limits to their validity

# M&V Plan Contents

- 7) Energy Prices: Identify if they will be fixed or variable for reporting purposes
- 8) Metering: Identify meter locations and spec's, Cx, and calibration procedures for all non-utility meters. Establish upper limit on acceptable data loss.
- 9) Monitoring Responsibilities: Identify responsible parties for data recording and reporting

# M&V Plan Contents

- 10) Expected Accuracy: Include meter tolerances, and uncertainty associated with sampling error and any engineering calculations
- 11) Budget: Include setup cost and on-going reporting costs
- 12) Report Format: Include a sample report
- 13) Quality Assurance: Specify steps taken towards QA of savings calculation & reporting



# M&V Reporting

- Must follow procedures identified in the M&V Plan
- Include:
  - Complete data sets (justification for any “corrected” data)
  - Description and justification of adjustments
  - Any estimated values
  - Energy price schedule
  - Savings in energy and monetary units

# Example:

- 320,000ft<sup>2</sup> office building in Eastern MA with extensive sub-metering
- Option C (sub-facility level), not weather-normalized, baseline still being developed (new facility)

# Electricity Use

Sub-Totals					
Raw Values	November	December	%Δ Nov-Dec	January	%Δ Dec-Jan
Outdoor Lighting	3,364	3,548	5.46%	3,523	-0.7%
1st Floor - Lights	15,619	16,861	7.95%	16,987	0.7%
1st Floor - Motors	487	501	2.77%	533	6.1%
2nd Floor - Lights	15,925	17,797	11.76%	17,578	-1.2%
2nd Floor - Motors	2,569	3,024	17.71%	3,138	3.6%
3rd Floor - Lights	15,928	17,563	10.26%	17,094	-2.7%
3rd Floor - Motors	2,838	5,293	86.52%	3,149	-68.1%
RTUs	47,022	45,174	-3.93%	38,133	-18.5%
UPS	20,047	20,608	2.80%	20,552	-0.3%
Lieberts	25,765	21,660	-15.93%	20,954	-3.4%
Kitchen Mechanical	6,293	6,413	1.90%	5,813	-10.3%
Kitchen Lights	4,719	4,810	1.94%	4,604	-4.5%
HVAC other	24,276	24,669	1.62%	24,118	-2.3%
Receptacles, Misc. Loads	94,952	100,403	5.74%	110,267	8.9%
Kitchen Exhaust (included in KL41 meter)	1,977	1,977	0.00%	1,950	-1.4%
HW Pumps (included in MP41 meter)	1,861	1,861	0.00%	2,364	21.3%


# Natural Gas Use

	November	December	January	unit	%Δ Nov-Dec	%Δ Dec-Jan
Kitchen Gas	117,100	146,600	121,700	cubic ft	25.2%	-17.0%
Main Gas	337,000	852,000	962,000	cubic ft	152.8%	12.9%
Total Gas	454,100	998,600	1,083,700	cubic ft	119.9%	8.5%
% Kitchen Gas	25.79%	14.68%	11.23%			
% Main Gas	74.21%	85.32%	88.77%			




# One-Month End-Use Reconciliation

January 2010 Electricity End-Use Reconciliation




Total KWh = 286,000



# Monthly Electric Use Comparison



# Monthly Gas Use Comparison




# Example:


- A 95,700ft<sup>2</sup> office building in Eastern MA. RCx project began late 2008 continuing through 2009
- Option D: Baseline and Post-RCx both modeled in Trane TRACE
- Reporting Period: April 2009 – March 2010 (Electrical) and November 2007 – September 2008 (Gas)




# Electricity Use: Model Compared with Actual




# Electrical Use: Historical



# Electric Demand: Model Compared with Actual



# Electric Demand: Historical



# Natural Gas Use: Model Compared with Actual

