

# Existing Building Commissioning

## *Bringing It All Together: EBCx Case Study*



# Case Study Overview

- University campus
- EBCx of 3 laboratory / classroom facilities
- Buildings varied in age: 1975, 1994, 2009
- Focus on HVAC systems
- Largely based on trend and screenshot reviews
- Used Johnson Metasys BMS

# EBCx Process

- Kickoff Meeting:
  - Establish objectives, schedule, team-member roles, data requirements
  - Brainstorming and building data review to select and prioritize
  - Collect available drawings and building system information
- Data Gathering & Preliminary Review:
  - Review drawings, control sequences & schematics
  - Gain understanding of systems
  - Establish baseline conditions
  - Identify potential opportunities
  - Review screenshots of major systems

# EBCx Process (cont...)

## ■ Trend Data Review:

- Preliminary review to ensure formatting & quality
- Graphical analysis
- Statistical analysis


## ■ Measure Development:

- Establish current conditions
- Identify issue and duration
- Field verification
- Determine what needs to be fixed – how to make it better?
- Who's going to fix it?
- Define how measure saves energy

# EBCx Process (cont...)

- Energy & Resource Savings:
  - Determine level of detail required for analysis
  - Quantify energy & resource savings – spreadsheets or models
  - Increased energy?
  - Identify key assumptions and inputs
- Cost Estimates: get quotes where possible
- Implementation: work with contractors and/or building staff
- Measurement & Verification
  - Use trend data where possible
  - Field verify and/or use work orders or contractor invoices to verify


# Leaking Steam Valve: Screenshot



- Field verification found valve sticking open

# Leaking Steam Valve: Trend Data

- Trend data from BMS confirms issue – began on October 31.





# Leaking Steam Valve: Energy Savings Calculations

- Where do savings come from?
  - Wasted steam energy
  - Unnecessary cooling energy
- How to calculate savings?
  - ...with trends of airflow and temperature it's easy!
  - $Q_{\text{Btu/hr}} = 1.08 \times \text{FLOW}_{\text{CFM}} \times [T_{\text{in}} - T_{\text{out}}]$
  - Count steam savings when steam should not be needed
  - Count CHW savings when CHW valve open and steam valve closed
  - What is duration of issue and savings?



# Leaking Steam Valve: Key Assumptions, Inputs, & Parameters

- Important to state key assumptions!

Input Parameters & Key Assumptions		
Steam System Delivery Efficiency	85%	
Chiller System Delivery Efficiency	90%	
CHW Plant Electric Efficiency	0.60	kW/ton
Estimated Avg RA Temp	72	F
Fan Full-load Power	52.7	BHP
Fan Full-load Power	42.7	kW
Affinity Exponent for Supply Fan	2.5	
Electric Avg Unit Cost	\$0.075	\$/kWh
Steam Avg Unit Cost	\$13.00	\$/MMBtu
*Steam savings only when stm valve closed & PHT>MAT+FanT		
*CHW savings only when steam leaking & CHW valve open		

# Leaking Steam Valve: Energy Savings Calculations

Min	13	0	-4	16.2	0	0	0.0	0.0	0	35	0	36	0	0	0.0
Max	93	100	36,111	86.8	41,373	100	42.7	11.0	100	148	100	105	1,619,005	2,674,970	74.5
Average	42	97	16,349	48.1	20,501	51	11.0	1.8	2	104	35	58	1,194,578	1,036,778	55.9
Date / Time	OA-T (F)	OA-DPR (% open)	OA-FLW (cfm)	Calc'd MAT (F)	SF-FLW (cfm)	SF-SPD (%)	Calc'd Fan Pwr (kW)	Calc'd Fan dT (F)	1-3-VLV (% open)	PH-T (F)	CLG-VLV (% open)	DA-T (F)	Chris Steam Q (Btu/hr)	Chris CHW Q (Btu/hr)	Calc'd Lkg dT (F)
1/3/12 11:30:00 AM EST	24.8	100	28,175	31.9	33,168	86	29.3	3.5	0	77.5	14.03	64.8	1,508,790	457,170	42.1
1/3/12 11:45:00 AM EST	25.0	100	28,003	32.3	33,201	87	29.9	3.6	0	76.3	13.67	64.2	1,445,198	433,221	40.3
1/3/12 12:00:00 PM EST	24.3	100	28,021	31.8	33,207	86	29.1	3.5	0	74.9	12.23	63.0	1,421,949	429,147	39.6
1/3/12 12:15:00 PM EST	24.1	100	28,059	31.4	33,047	85	28.4	3.4	0	75.1	10.31	63.2	1,439,892	426,614	40.3
1/3/12 12:30:00 PM EST	24.1	100	27,729	31.6	32,875	86	29.2	3.5	0	76.0	9.70	64.6	1,451,068	404,786	40.9
1/3/12 12:45:00 PM EST	24.1	100	27,940	31.4	32,961	84	27.3	3.3	0	76.4	9.37	65.1	1,484,979	405,435	41.7
1/3/12 1:00:00 PM EST	24.6	100	27,580	32.1	32,781	86	29.4	3.6	0	76.9	9.71	65.5	1,457,885	402,885	41.2
1/3/12 1:15:00 PM EST	24.4	100	27,590	31.3	32,290	85	28.5	3.5	0	76.8	9.92	65.3	1,463,650	402,372	42.0
1/3/12 1:30:00 PM EST	24.6	100	27,178	32.4	32,583	84	28.0	3.4	0	77.0	10.63	65.7	1,446,854	397,778	41.1
1/3/12 1:45:00 PM EST	24.4	100	27,223	32.0	32,418	84	27.6	3.4	0	76.3	10.74	65.1	1,432,904	394,047	40.9
1/3/12 2:00:00 PM EST	24.6	100	27,068	32.5	32,471	84	27.4	3.4	0	76.5	10.95	65.3	1,426,997	395,628	40.7
1/3/12 2:15:00 PM EST	24.6	100	27,199	32.2	32,421	84	28.0	3.4	0	76.1	10.95	65.1	1,415,267	386,343	40.4
1/3/12 2:30:00 PM EST	24.8	100	27,283	32.1	32,245	84	27.6	3.4	0	76.5	10.95	65.3	1,429,204	391,319	41.0
1/3/12 2:45:00 PM EST	24.8	100	26,864	31.9	31,657	83	27.2	3.4	0	76.7	11.05	65.1	1,414,047	398,436	41.4
1/3/12 3:00:00 PM EST	24.8	100	27,214	31.8	31,981	83	27.2	3.4	0	75.9	10.94	64.7	1,404,717	387,842	40.7
1/3/12 3:15:00 PM EST	24.6	100	27,040	32.0	32,059	85	28.4	3.5	0	75.3	10.13	64.1	1,375,091	387,666	39.7
1/3/12 3:30:00 PM EST	24.4	100	27,284	31.7	32,242	84	27.3	3.4	0	74.6	8.86	63.7	1,376,195	381,331	39.5
1/3/12 3:45:00 PM EST	24.4	100	27,262	31.4	31,970	83	26.5	3.3	0	74.2	7.90	63.9	1,363,294	356,793	39.5
1/3/12 4:00:00 PM EST	24.2	100	27,244	31.6	32,254	84	27.5	3.4	0	73.8	6.94	64.1	1,351,079	338,466	38.8


# Leaking Steam Valve: Energy Savings & Project Economics

- Present energy savings in energy units and costs
- Annualize savings when possible
- Perform cost estimate for implementation/repair


Leaking Steam Valve Wasted Energy		
Avg dT between PHT & DAT	55.9	F
<b>Annual Steam Energy Savings</b>	<b>4,193</b>	<b>MMBtu/yr</b>
Annual Steam Cost Savings	\$54,513	
Annual Chiller Energy Savings	3,395	MMBtu/yr
Annual Chiller Energy Savings	282,930	ton-hrs/yr
<b>Annual Chiller Energy Savings</b>	<b>169,758</b>	<b>kWh/yr</b>
Annual Chiller Cost Savings	\$12,732	
<b>Total Cost Savings</b>	<b>\$67,245</b>	

ISB-2: AHU 2.2 - Leaking Steam Valve		
Annual Steam Energy Savings	4,193	MMBtu/yr
Annual Steam Cost Savings	\$54,513	\$/year
<b>Annual Electric Energy Savings</b>	<b>169,758</b>	<b>kWh/year</b>
Average Demand Reduction	19.4	kW/month
Annual Electric Cost Savings	\$12,732	\$/year
Total Cost Savings (\$/year)	\$67,245	\$/year
Estimated Implementation Cost	\$2,100	
Project Simple Payback (years)	0.03	years
Project ROI	3202%	

# Leaking Steam Valve: Implementation & Verification



# Leaking CHW Valve: Screenshot




- Field verification found actuator incorrectly operating one valve



# Leaking CHW Valve: Trend Data

- Trend data from BMS confirms issue.



# Leaking CHW Valve: Energy Savings Calculations

- Where do savings come from?
  - Wasted CHW energy
  - Unnecessary steam energy
- How to calculate savings?
  - ...with trends of airflow and temperature it's easy!
  - $Q_{\text{Btu/hr}} = 1.08 \times \text{FLOW}_{\text{CFM}} \times [T_{\text{in}} - T_{\text{out}}]$
  - Count steam savings when steam valve open and CHW valve closed
  - Count CHW savings when CHW valve closed & cooling occurring
  - What is duration of issue and savings?



# Leaking CHW Valve: Key Assumptions, Inputs, & Parameters

- Important to state key assumptions!

Input Parameters & Key Assumptions		
Steam System Delivery Efficiency	85%	
Chiller System Delivery Efficiency	90%	
CHW Plant Electric Efficiency	0.60	kW/ton
Estimated Avg RA Temp	72	F
Fan Full-load Power	124.8	bhp
Fan Full-load Power	101.2	kW
Affinity Exponent for Supply Fan	2.5	
Electric Avg Unit Cost	\$0.075	\$/kWh
Steam Avg Unit Cost	\$13.00	\$/MMBtu
*CHW savings only when PHT>DAT & CHW valve closed		
*Steam savings only when steam valve open & CHW closed		

# Leaking CHW Valve: Energy Savings Calculations

Min	26	32,534	0	0	62	0	50	0	0	0.0
Max	68	50,133	100	100	131	100	64	3,038,072	3,038,072	73.8
Average	46	39,623	100	41	87	100	60	1,159,778	1,159,538	27.3
Date / Time	OA-T (F)	SF-FLW (cfm)	1-3-VLV (% open)	2-3-VLV (% open)	PH-T (F)	CLG-VLV (% open)	DA-T (F)	Steam Q (Btu/hr)	CHW Q (Btu/hr)	Calc'd Lkg dT (F)
10/24/12 10:00:00 AM EDT	51.3	46,117	48	0	86.7	0	60.5	1,305,175	1,305,175	26.2
10/24/12 10:15:00 AM EDT	51.1	46,362	52	0	84.4	0	59.7	1,237,455	1,237,455	24.7
10/24/12 10:30:00 AM EDT	51.3	46,441	57	0	86.6	0	60.1	1,330,468	1,330,468	26.5
10/24/12 10:45:00 AM EDT	51.3	46,454	53	0	87.0	0	60.3	1,342,459	1,342,459	26.8
10/24/12 11:00:00 AM EDT	52.0	46,180	48	0	86.8	0	60.3	1,323,816	1,323,816	26.5
10/24/12 11:15:00 AM EDT	51.5	46,418	49	0	84.2	0	59.9	1,220,987	1,220,987	24.4
10/24/12 11:30:00 AM EDT	51.8	46,667	53	0	125.5	0	68.8	2,857,928	2,857,928	56.7
10/24/12 11:45:00 AM EDT	52.2	46,416	0	0	68.2	0	53.7	0	724,841	14.5
10/24/12 12:00:00 PM EDT	51.7	46,815	0	0	62.7	0	51.0	0	591,280	11.7
10/24/12 12:15:00 PM EDT	51.9	47,003	0	0	61.9	0	50.6	0	573,066	11.3
10/24/12 12:30:00 PM EDT	52.1	46,692	0	0	61.7	0	50.4	0	569,220	11.3
10/24/12 12:45:00 PM EDT	52.6	46,565	0	0	61.9	0	50.4	0	577,774	11.5
10/24/12 1:00:00 PM EDT	52.8	46,672	0	0	61.9	0	50.4	0	579,104	11.5
10/24/12 1:15:00 PM EDT	53.1	46,767	100	100	119.7	0	61.6	2,936,158	2,936,158	58.1
10/24/12 1:30:00 PM EDT	53.1	46,728	0	41	83.9	0	59.9	1,212,941	1,212,941	24.0
10/24/12 1:45:00 PM EDT	53.7	46,709	0	47	87.8	0	59.7	1,418,251	1,418,251	28.1
10/24/12 2:00:00 PM EDT	53.4	47,062	0	49	87.8	0	59.9	1,420,097	1,420,097	27.9
10/24/12 2:15:00 PM EDT	53.9	46,887	0	44	88.9	0	60.7	1,428,850	1,428,850	28.2




# Leaking CHW Valve: Energy Savings & Project Economics

- Present energy savings in energy units and costs
- Annualize savings when possible
- Perform cost estimate for implementation/repair

Improper Cooling Valve Wasted Energy		
Avg dT between PHT & DAT for past month	27.3	F
Wasted CHW energy for month to date	778	MMBtu/yr
Wasted steam energy for month to date	823	MMBtu/yr
Months savings applied to for year	5.0	months/yr
Annualized Chiller Energy Savings	3,888	MMBtu/yr
Annualized Chiller Energy Savings	324,040	ton-hrs/yr
<b>Annualized Chiller Energy Savings</b>	<b>194,424</b>	<b>kWh/yr</b>
Annualized Chiller Cost Savings	\$14,582	
<b>Annualized Steam Energy Savings</b>	<b>4,117</b>	<b>MMBtu/yr</b>
Annualized Steam Cost Savings	\$53,524	
<b>Total Cost Savings</b>	<b>\$68,106</b>	

ISB-4: AHU 1.4 - Faulty Cooling Valve Actuation		
Annual Steam Energy Savings	4,117	MMBtu/yr
Annual Steam Cost Savings	\$53,524	\$/year
<b>Annual Electric Energy Savings</b>	<b>194,424</b>	<b>kWh/year</b>
Average Demand Reduction	22.2	kW/month
Annual Electric Cost Savings	\$14,582	\$/year
Total Cost Savings (\$/year)	\$68,106	\$/year
Estimated Implementation Cost	\$1,200	
Project Simple Payback (years)	0.02	years
Project ROI	5675%	

# Leaking CHW Valve: Implementation & Verification



# EBCx Case Study Summary

EEM	EEM Name	Electric Demand Savings (kW)	Electric Energy Savings (kWh/yr)	Electric Cost Savings (\$/year)	Steam Savings (MMBtu /yr)	Steam Cost Savings (\$/yr)	Total Cost Savings (\$/yr)	Project Cost Estimate (\$)	Simple Payback (years)
<b>Science Building</b>									
SB-1	Fan Speed Reduction on AHU 2.1 & 2.2	9.1	79,996	\$6,000	0	\$0	\$6,000	\$3,000	0.5
SB-2	Repair Steam Valve on AHU 2.2	19.4	169,783	\$12,734	4,193	\$54,509	\$67,243	\$2,100	0.0
SB-3	Repair Cooling Valve on AHU 2.1	3.8	33,329	\$2,500	426	\$5,538	\$8,038	\$900	0.1
SB-4	Repair Cooling Valve on AHU 1.4	22.2	194,424	\$14,582	4,117	\$53,521	\$68,103	\$1,200	0.0
SB-5	Optimize Heat Wheels on AHUs 1.1-1.4	11.9	103,809	\$7,786	0	\$0	\$7,786	\$8,800	1.1
<b>Subtotals</b>		<b>66.4</b>	<b>581,341</b>	<b>\$43,601</b>	<b>8,736</b>	<b>\$113,568</b>	<b>\$157,169</b>	<b>\$16,000</b>	<b>0.1</b>
<b>Research Center</b>									
RC-1	Install VFDs on EFs & Reduce Airflow	42.0	365,400	\$27,405	0	\$0	\$27,405	\$75,977	2.8
RC-2	Install VFDs on HW Reheat Pumps	11.0	96,557	\$7,242	0	\$0	\$7,242	\$19,173	2.6
RC-3	Install VFDs on HW Radiation Pumps	4.4	25,898	\$1,942	0	\$0	\$1,942	\$16,049	8.3
<b>Subtotals</b>		<b>57.4</b>	<b>487,855</b>	<b>\$36,589</b>	<b>0</b>	<b>\$0</b>	<b>\$36,589</b>	<b>\$111,199</b>	<b>3.0</b>
<b>Grad Research</b>									
GR-1	AHUs 8 & 16: Repair Steam Valves & Return Units to Normal Schedule	0.0	59,643	\$4,473	1,015	\$13,195	\$17,668	\$3,800	0.2
<b>Subtotals</b>		<b>0.0</b>	<b>59,643</b>	<b>\$4,473</b>	<b>1,015</b>	<b>\$13,195</b>	<b>\$17,668</b>	<b>\$3,800</b>	<b>0.2</b>
<b>OVERALL TOTALS</b>		<b>124</b>	<b>1,128,839</b>	<b>\$84,663</b>	<b>9,751</b>	<b>\$126,763</b>	<b>\$211,426</b>	<b>\$130,999</b>	<b>0.6</b>